

**SIGNS TO DOORS, LOUVRES AND TRANSFORMER SAFETY BARRIERS**

EXTERNAL SOLID CORE DOORS

"FIRE SAFETY DOOR – DO NOT OBSTRUCT" 20mm. OUTSIDE  
 "DANGER HIGH VOLTAGE – KEEP OUT" 350 x 175 FIGURE 1 AS DETAILED

EXTERNAL FIRE DOORS

"FIRE SAFETY DOOR – DO NOT OBSTRUCT" 20mm. OUTSIDE  
 "FIRE DOOR DO NOT OBSTRUCT – DO NOT KEEP OPEN" 20mm. OUTSIDE  
 "DANGER HIGH VOLTAGE – KEEP OUT" 350 x 175 FIGURE 1 AS DETAILED

INTERNAL FIRE DOORS

"FIRE DOOR DO NOT OBSTRUCT – DO NOT KEEP OPEN" 20mm. OUTSIDE  
 "DANGER HIGH VOLTAGE – KEEP OUT" 350 x 175 FIGURE 1 AS DETAILED

LOUVRE DOORS

"DANGER HIGH VOLTAGE – KEEP OUT" 350 x 175 FIGURE 1 AS DETAILED

FIXED PANELS

"DANGER HIGH VOLTAGE – KEEP OUT" 350 x 175 FIGURE 1 AS DETAILED

NOT LESS THAN 1x SIGN PER 6 METRE LENGTH OF FIXED LOUVRES

**SWITCHGEAR ARC FLASH HAZARD WARNING SIGN** 350 x 175 FIGURE 2 AS DETAILED

FIGURE 1  
 DANGER SIGN FOR DOORS, LOUVRES AND TRANSFORMER SAFETY BARRIERS





FIGURE 2  
 ARC FLASH HAZARD WARNING SIGN



**BCA REQUIREMENTS**

FIRE DOOR SIGNS \_\_\_\_\_ FIRE DOOR DO NOT OBSTRUCT DO NOT KEEP OPEN \_\_\_\_\_ D2.23(b)  
 FIRE ESCAPE DOOR \_\_\_\_\_ FIRE SAFETY DOOR - DO NOT OBSTRUCT \_\_\_\_\_ D2.23(b)


**AUSTRALIAN STANDARDS**

SAFETY SIGNS \_\_\_\_\_ AS1319  
 DANGER SIGNS \_\_\_\_\_ AS1319

**ENERGY NETWORKS ASSOCIATION**

SIGN SCHEDULE \_\_\_\_\_ ENA 015

					The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2020.  ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2020.
B	CHANGE TITLE BLOCK & LOGO, CHANGED SIGN	12/02/2008	AC	GA	
C	LOGO AND REFERENCES UPDATED	23/02/2018			
D	ADDED DETAILS FOR ARC FLASH HAZARD SIGNAGE	23/07/2020	N. Azizi	W. Cleland	
No	Revision	Date	Checked	Approved	

 SIGNS FOR INDOOR CHAMBER SUBSTATION		Drawn:	Date:
		Designed: A-NNR	Checked:
Project No: _____ Status: <b>Current</b> Work Pack No: _____ File: _____		Approved: A-NNR	
		A4	094-009