



NOTES

1. TREES MUST BE PRUNED TO MAINTAIN THE MINIMUM CLEARANCE;
 - FOR BUSH FIRE AREA, TREES < 3m: TREE HEIGHT AND BRANCHS MUST BE PRUNED TO < 3m HEIGHT AND MAINTAIN THE MINIMUM CLEARANCE OF 10m;
 - FOR BUSH FIRE AREA, TREES > 10m: TREE HEIGHT AND BRANCHS MUST BE PRUNED TO A HEIGHT EQUAL TO THE CLEARANCE FROM ZONE SUBSTATION;
 - FOR NON-BUSH FIRE AREA, TREES < 3m: TREE HEIGHT AND BRANCHS MUST BE PRUNED TO < 3m HEIGHT AND MAINTAIN THE MINIMUM CLEARANCE OF 3m;
 - FOR NON-BUSH FIRE AREA, TREES > 3m: TREE HEIGHT AND BRANCHS MUST BE PRUNED TO A HEIGHT EQUAL TO THE CLEARANCE FROM ZONE SUBSTATION;
2. BRANCHES MUST NOT OVERHANG IN "NO TREE & FALL IN HAZARD ZONE" AND NO TREES PERMITTED IN THIS ZONE.
3. ALL PRUNING MUST COMPLY WITH AS4373 PRUNING OF AMENITY TREE STANDARD.
4. WELL MAINTAINED GRASS AND SHRUBS UP TO 1m HEIGHT ARE ALLOWED IN NO TREE ZONE.

		Drawn: K. Vedanti		Designed: K. Vedanti		evoenergy		Scale: N.T.S	Date: 11/05/2022	Sheet No:
		Checked: N. Azizi		28/06/2022		VEGETATION CLEARANCE REQUIREMENTS FOR EVOENERGY ZONE SUBSTATIONS IN ACT AND NSW		Work Pack No:	File:	
		Approved: W. Cleland		28/06/2022				Status: Current		
A		STATUS UPDATED - KV		10/10/2022						
No		Revision		Date		Checked		Approved		Rev A
The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2018.										