

A

B

C

D

E

F

A

B

C


D

E


F

NOTES:


- THIS DRAWING DOES NOT REPLACE ANY SEPARATION, COVER REQUIREMENT, TRENCH AND/OR CONDUIT ARRANGEMENT DRAWINGS. THIS DRAWING IS ONLY APPLICABLE FOR CONDUITS IN THE BRIDGE.
- THE CONDUIT SIZE IN ALL CASES MUST BE 150MM UPVC IN LINE WITH CIVIL WORKS MANUAL VOL2.
- SEPARATION BETWEEN THE EDGES OF THE CONDUIT MUST BE 100mm MINIMUM UNLESS NOTED.
- THE TRANSITION BETWEEN STANDARD DEPTH AND REDUCED DEPTH MUST BE GRADUAL WITHOUT USE OF 90° CONDUIT BENDS. DUE TO SITE SPECIFIC REASONS, REQUEST COORDINATOR MAY ACCEPT CONDUIT BENDS SUBJECTED TO NO INCREASED RISK DURING CABLE HAULING.
- CLEAR VISIBLE PERMANENT SURFACE MARKERS AT 3 METRE INTERVALS ALONG THE CABLE ROUTE IN THE BRIDGE ARE REQUIRED. THE MARKERS SHOULD BE CENTRALLY AFFIXED ABOVE AND/OR BELOW THE CONDUITS (BY STAINLESS STEEL MUSHROOM HEAD STRIKE ANCHOR) TO ALL SURFACES (INCLUDING FLOOR, CEILINGS, CABLE RISERS, WALLS AND BEAMS). SUITABLE MARKING CONSIST A MINIMUM 150mm X 65mm STAINLESS STEEL WARNING PLATE WITH THE WORDS "DANGER, ELECTRICAL CABLE. REDUCED COVER".
- FOLLOWING EARTHING NOTES MUST BE CONVEYED TO DEVELOPER AND MUST BE CONSIDERED IN THEIR RISK ASSESSMENT:
 - EARTHING IF REQUIRED MUST BE ASSESSED, DESIGNED AND VALIDATED IN ACCORDANCE WITH THE EVOENERGY DOCUMENT "PO07127-DISTRIBUTION EARTHING DESIGN AND CONSTRUCTION MANUAL".
 - MINIMUM SEPARATION REQUIREMENTS FROM ANY CONDUCTIVE BURIED ITEM OR CONDUCTIVE STRUCTURE ABOVE THE GROUND TO ANY EVOENERGY 11kV NETWORK EARTHING MUST BE DETERMINED ON A CASE BY CASE BASIS BY A DESIGNER OR NETWORK SERVICES SECTION MANAGER.
 - ALL LOW VOLTAGE EARTHING MUST BE POSITIONED IN ACCORDANCE WITH EVOENERGY DOCUMENT "PO07127-DISTRIBUTION EARTHING DESIGN AND CONSTRUCTION MANUAL" AND MAINTAIN A MINIMUM 4m SEPARATION TO ANY EVOENERGY 11kV EARTHING INFRASTRUCTURE, FOR EXAMPLE STREET LIGHT EARTHING.
- CABLE/CONDUITS UNDER BRIDGE CARRIAGEWAY ARE NOT ACCEPTABLE, HOWEVER, INSTALLATION UNDER THE PEDESTRIAN WAY MAY BE ACCEPTABLE UNDER THE FOLLOWING CONDITIONS:
 - MINIMUM COVER ABOVE THE TOP OF THE CONDUIT MUST BE 300mm AND MAY CONSIST OF CONCRETE, STEEL, VOID OR MATERIAL SUBJECT TO BRIDGE DESIGN AND RISK ASSESSMENT/SAFETY IN DESIGN REPORT.
 - IF LOCATION HAS OTHER ASSETS OR SERVICES, SEPARATION MUST COMPLY WITH DRAWING 3832-018.
 - IF CONDUIT IS INSTALLED IN A VOID, CLEATS AND SPACERS MUST BE UTILISED TO PREVENT CABLE MOVEMENT, INCLUDING UNDER FAULT CONDITIONS AND TO ENSURE 100MM SEPARATION OF THE CONDUITS.
 - VOIDS MUST INCLUDE MITIGATION TO PREVENT VERMIN ACCESS.
 - VOIDS MUST HAVE SUITABLE DRAINAGE TO PREVENT ACCUMULATION OF LIQUIDS. ENCASMENTS UTILISING CONCRETE, STEEL OR ANY OTHER MATERIAL MUST BE WATER SEALED
 - VOIDS MUST BE ACCESSIBLE FROM THE TOP BY THE REMOVAL OF SLABS OR COVERS. THE CLASS OF COVER MUST BE COMPATIBLE WITH INTENDED USE I.E. IF PEDESTRIAN WAY ALLOWS USE OF EMERGENCY VEHICLES, COVERS MUST BE APPROPRIATELY RATED.
 - IF SURFACE BENEATH CONDUITS IS ACCESSIBLE, MINIMUM COVER TO BENEATH OF CONDUIT MUST BE 200MM. IF SURFACE BENEATH CONDUITS IS INACCESSIBLE, MINIMUM COVER MAY BE REDUCED TO 100MM.
 - MAXIMUM RUN AT REDUCED COVER IN A BRIDGE IS 450m WITH MAXIMUM 90° DEVIATION BY SINGLE 90° OR TWO 45° LARGE SWEEPING BENDS.
 - SPARE CONDUIT REQUIREMENTS MUST BE CONSULTED WITH PLANNING SECTION.
 - THE STRUCTURAL STRENGTH OF THE BRIDGE AND THE EFFECTS ON EVOENERGY CABLES AND CONDUITS BY BRIDGE EXPANSION, CONTRACTION, SETTLEMENT AND VIBRATION MUST BE ADEQUATELY ADDRESSED IN IN THE SAFETY IN DESIGN REPORT. MITIGATION SUCH AS CONDUIT SLIP JOINTS, FLEXIBLE JOINTS AND CABLE SNAKES MUST BE DETAILED.
 - MODIFICATION TO CONDUITS IN EXISTING BRIDGES TO BE ASSESSED INDIVIDUALLY.
 - LIGHT WEIGHT MATERIAL SUCH AS POLYSTYRENE MAY BE USED TO ENCASE CONDUITS TO REDUCE WEIGHT OF BRIDGE SECTION. THE LIGHT WEIGHT MATERIAL MUST BE ENCASED IN 100mm OF CONCRETE AND MUST NOT DERATE THE CABLE.
 - IF CONDUITS AT THE BRIDGE APPROACHES ARE DEEPER THEN 1.5m, CABLE DERATING MUST BE ASSESSED AND CONDUIT SPACING MAY NEED TO BE INCREASED.



Conduits in Pedestrian Bridge Cavity



Conduits in Pedestrian Bridge Deck and Beam



Sample Surface Marker see Note 8

				Drawn: J. Ryan	Designed: J. Primmer
				Checked: N. Azizi	27/02/2024
				Approved: W. Cleland	27/02/2024
No	Revision	Date	Checked	Approved	Project No:
The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2018.					
				ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2018.	

evoenergy	Scale: NTS	Date: 27/02/2024	Sheet No: 1 OF 1
	CONDUIT REQUIREMENTS FOR CABLE < 12kV IN BRIDGE STRUCTURES		
Status: Current			
A3	3832-022	Rev	