



PLAN VIEW of ELECTRICAL PIT and TELCO. PIT

TYPICAL TRENCH DETAIL

LARGE TRENCH DETAIL

NOTES:

- TELCO LEAD-IN LOCATIONS ARE SHOWN AS INDICATIVE ONLY.
- REFER TELCO DESIGN FOR APPROXIMATE LOCATIONS, TELCO PITS ARE NOT TO BE INSTALLED OVER GAS.
- CONTRACTOR IS TO CONFIRM THESE LOCATIONS ON-SITE AND ENSURE ALL MINIMUM CLEARANCES TO HYDRAULIC TIES AND OTHER SERVICES ARE MAINTAINED.
- ROAD BUILDER IS TO ACCURATELY IDENTIFY UTILITY CROSSINGS BY STAMPING THE KERB FACE WITH E/T WHERE APPLICABLE.
- WHERE P6 PITS ARE TO BE INSTALLED, THE TRENCH WILL NEED TO BE 100MM DEEPER.

- AT P8 LOCATIONS, THE TRENCH WILL NEED TO BE 200MM DEEPER, WHEREVER POSSIBLE, OFFSET LARGE PITS TO THE KERB AS SHOWN IN LARGE TRENCH DETAIL.
- ALL MEASUREMENT ARE IN MM UNLESS OTHERWISE NOTED.
- ALL DEVELOPER SUPPLIED TRENCHING, BACKFILLING, AND COMPACTION OPERATIONS ARE TO BE IN ACCORDANCE WITH THE SHARED TRENCH AGREEMENT FOR THE ACT 2014 AND EVOENERGY'S P00793 CIVIL WORKS FIELD MANUAL VOLUME 2.

No	Revision	Date	Checked	Approved
A	NOTE FOR SHARED TRENCH UPDATED - KV	7/02/2022	N. Azizi	W. Cleland
B	ELECTRICAL PIT UPDATED - KV	24/08/2022	N. Azizi	W. Cleland
C	VP'S TO SCALE & FITTED - DIMS ADJUSTED - TE	30/11/2023	N. Azizi	W. Cleland

evoenergy

The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy, 2021.

ACT Cadastral Information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2021.

Drawn: K. Vedanti	Designed: K. Vedanti
Checked: N. Azizi	3/09/2021
Approved: W. Cleland	3/09/2021
Project No:	

**UNDERGROUND SERVICES IN A SHARED TRENCH
ELECTRICAL PIT REQUIREMENT
UNDERGROUND RESIDENTIAL DISTRIBUTION
WITH GAS**

Scale: 1:20	Date: 3/09/2021	Sheet No:
Work Pack No:	File:	
Status:	Current	
A2	393-011	Rev C