



**NOTES:**

1. CONDUIT SIZE 50mm DIA. OR OPTIONAL RECTANGULAR OPENING FOR CABLE TRAY ENTRY.
2. CONDUIT OR OPENING LOCATION SHOWN ON DESIGN DRAWINGS.
3. ALL OPENINGS MUST BE SEALED/PLUGGED WITH FIRE STOPPING MATERIALS AFTER INSTALLATION OF THE CONSUMERS MAINS.

					The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2018.  ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2018.
D	LOGO AND REFERENCES UPDATED	18/03/2018	B. Suthar	W. Ibrahim	
C	UPDATED AS PART OF CHAMBER SUBSTATION STANDARDS REVIEW	29/11/2017	C. Desai	W. Ibrahim	
No	Revision	Date	Checked	Approved	

<p><b>HIGH LEVEL CONDUITS FOR CONSUMER MAINS ENTERING CHAMBER SUBSTATIONS STANDARD CONFIGURATION</b></p>		Drawn: SWR	Date: 15/01/1996	
		Designed: E. Amaratunga		
		Checked: M. Charlton		
		Approved: A-NNR		
Project No:	Status: Current	A4	4931-08	REV
Work Pack No:	File:			D