



- LEGEND**
- ① M6 x 50 mm STUD, 2 NUTS, 2 FLAT WASHERS, 1 SPRING WASHER
 - ② EVOENERGY SEALING STUD
 - ③ SERVICE FUSE MOUNTING BRACKET
 - ④ 5mm TAPPED
 - ⑤ 100A SERVICE FUSES
 - ⑥ LOCKING HINGE
 - ⑦ 50mm HOLE WITH BUSH
 - ⑧ 50mm HOLE NO BUSH/CABLE ENTRY
 - ⑨ NEUTRAL LINK

- MANUFACTURING NOTES**
1. MATERIAL: FOLDED 1.5mm ZINCSEAL.
 2. COLOUR: TRANSFORMER GREY.
 3. ALL MULLIONS, JOINTS & CORNERS WELDED & FINISHED TO FORM A FLAT SURFACE.
 4. PRIOR TO PAINTING ALL SURFACES THOROUGHLY CLEANED FREE FROM SCALE & RUST ETC.
 5. ALL METAL TREATED WITH POLYESTER POWDER COATING.
 6. EXTERNAL DOORS ARE HINGED WITH CHROME PLATED PIN HINGES & LOCKED USING LOWE & FLETCHER T LOCKS.
 7. INTERNAL PANELS HINGED WITH 75mm BUTT HINGES & SCREWED.
 8. EQUIPMENT IDENTIFIED BY ENGRAVED PVC LABELS - WHITE MATERIAL / BLACK LETTERS.
 9. THE NEUTRAL LINK MUST BE SUITABLE FOR 2x16-35mm² CABLE AND MUST HAVE TWO SCREWS PER TERMINAL.
 10. THE NEUTRAL LINK MUST HAVE SEALABLE COVER.
 11. THIS DRAWING MUST BE READ IN CONJUNCTION WITH EVOENERGY LOW VOLTAGE POINT OF ENTRY CUBICLE REQUIREMENTS - P007174 INCLUDING EARTHING REQUIREMENTS.

- INSTALLATION NOTES**
1. BOX TO BE RECESSED INTO WALL
 2. 2.3m - 2.8m MOUNTING HEIGHT (TO TOP OF BOX)
 3. 50mm ϕ HD CONDUIT CONTINUOUS FROM BOUNDARY UP CAVITY TO BOX (REFER DRAWING 8912-02 AND 8912-03)

		Drawn: C. Deschamps		Designed: Comm. & Mech. S/Boards		evoenergy		Scale: 1:5	Date:	Sheet No: 1 of 1
B	LOGO AND REFERENCES UPDATED TO EVOENERGY	8/01/2018	C. Desai	W. Ibrahim	Checked:			Work Pack No:	File:	
A	UPDATED FOR POWER OF CHOICE REFORMS	2/11/2017	C. Desai	W. Ibrahim	Approved: G. Astbury	P.O.E. / FUSE BOX FOR DOMESTIC & SMALL COMMERCIAL CUSTOMERS (16mm ² U/G SERVICES)		Status: Current	A3 8913-22-02 Rev C	
C	UPDATED NOTES (MS)	19/07/2022	N. Azizi	W. Cleland	Project No:					
No	Revision	Date	Checked	Approved	ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2017.					